

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CER/064/2025-26

Dated: 03/10/2025

It is certified that an inspection team headed by Dr. Rajesh Yadav with Team (Name of Officers with designation) from C.H.C. Bilariyaganj, Azamgarh, U.P. PHED inspected the SHRI RANJEET SINGH INTERNATIONAL SCHOOL AND COLLEGE, RAUNAPAR , KADIPUR , AZAMGARH, UTTAR PRADESH - 276122 (Name & Address of the school) on 03/10/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no C/AZM/011 dated 30/09/2025 of District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Kolbaj Bahadur (Pragati Nagar), Azamgarh, U.P.-276001 (PHED Lab) certified that the SHRI RANJEET SINGH INTERNATIONAL SCHOOL AND COLLEGE ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 (One Year).

Signature with Seal: .....

Name : Dr. Rajesh Yadav  
Designation : Medical Officer I/C  
Name & Address of the Office / Department :  
C.H.C. Bilariyaganj, Azamgarh, U.P.  
Medical Officer I/C  
C.H.C. Bilariyaganj  
Azamgarh

To  
The Manager  
SHRI RANJEET SINGH  
INTERNATIONAL SCHOOL AND  
COLLEGE, RAUNAPAR , KADIPUR  
AZAMGARH, UTTAR PRADESH -  
276122  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

# WATER ANALYSIS REPORT



## District Level Water Analysis Laboratory

U. P. Jal Nigam (Rural), Kolbj Bahadur (Pragati Nagar),  
Azamgarh- 276001

NABL T-8677

Report No.: C/AZM/011		Date: 30.09.2025		No. of Pages: 1			
Customer Details							
Office Name and Address		S.R.S. International School & College Kadipur Raunapar, Azamgarh (U.P)					
Ref. Letter No. & Date		NA					
Basic Details of Sample							
District	Azamgarh		Block	Haraiya			
Gram Panchayat	Kadipur Raunapar		Village	Kadipur Raunapar			
Habitation	Main		Location	S.R.S. International School & College Kadipur Raunapar			
Water Source	R O ( Water)		Sample Code	C/AZM/SEPT/11			
Quantity of Sample	1000 mL (Normal), 500 mL		Sampling date	29.09.2025			
Sample Received Date	29.09.2025		Sample. collected by	Shibbu Prasad (Clerk)			
Sampling Method Used	NA		Sample Depositor	Shibbu Prasad (Clerk)			
Analysis Start Date	29.09.2025		Analysis Completion Date	30.09.2025			
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis		
			Acceptable Limit	Permissible Limit			
1	2		4	5	6		
1	Taste	Agreeable	Agreeable/Not Agree.	Agreeable/Not Agree.	IS 3025 (Part 8):1984		
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2018		
3	Turbidity (NTU) **	1.20	1	5	APHA 24rd Ed. 2130- Turbidity Method B: 2023		
4	pH **	6.69	6.5-8.5	6.5-8.5	APHA 24rd Ed. 4500 H+ Method B: 2023		
5	Colour (Hazen units) **	0.00	5	15	APHA 24rd Ed. 2120- B (Platinum Cobalt Visual Comparison): 2023		
6	Total Dissolved Solids, mg/l **	110	500	2000	APHA 24rd Ed. 2540- TDS Method C (Dried at 180 degree Celsius):2023		
7	Chloride (as Cl), mg/l **	68	250	1000	APHA 24rd Ed. 4500- CL Method B (Argentometric Method):2023		
8	Total Alkalinity, (as CaCO <sub>3</sub> ) mg/l **	82	200	600	APHA 24rd Ed. 2320- Alkalinity Method B (Titration method):2023		
9	Total Hardness, (as CaCO <sub>3</sub> ) mg/l **	98	200	600	APHA 24rd Ed. 2340-Hardness Method C (EDTA Method):2023		
10	Calcium (as Ca), mg/l **	42	75	200	APHA 24rd Ed. 3500- Ca Method B (EDTA Method):2023		
11	Magnesium (as Mg), mg/l **	52	30	100	APHA 24rd Ed. 3500- Mg Method B (By Calculation):2023		
12	Sulphate (as SO <sub>4</sub> ), mg/l **	9.85	200	400	APHA 24rd Ed. 4500- SO <sub>4</sub> Method C (Gravimetric Method Ignition of Residue): 2023		
13	Nitrate (as NO <sub>3</sub> ), mg/l **	2.12	45	No relaxation	APHA 24rd Ed. 4500- NO <sub>3</sub> Method E (Cadmium Reduction Method): 2023		
14	Fluoride (as F), mg/l **	BDL(0.648)	1.00	1.50	APHA 24rd Ed. 4500-F Method C (Electrode Method):2023		
15	Iron (as Fe), mg/l **	BDL(0.001)	1.00	No relaxation	APHA 24rd Ed. 3111 -Fe Method B Direct A-Ac Flame AAS Method:2023		
16	Arsenic	BDL(0.001)	0.010	0.010	IS 3025 (Part 37): 1987 Silver diethyl Dithiocarbamate Method		
17	E.coli	0.0	0.0	0.0	Membrane Filter Method		
18	Total Coliform	0.0	0.0	0.0	Membrane Filter Method		

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.  
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.  
3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.  
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.  
5. Parameters above Permissible Limit are written in bold.  
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.  
7. Sample is not Collected by Lab.  
8. \*\* Indicates Parameters are NABL Accredited.

ARVIND KR CHATURVEDI  
(Report Prepared by)

SANDEEP KUMAR  
(Report Authorized by)

Laboratory Contact Details:

Email: sandeepkumar181092@gmail.com

Mobile No.: 8953458042